






















PLAN DRAWING SYMBOL SHEET

	FIRE RESISTING CONSTRUCTOR		CARBON DIOXIDE EXTINGUISHER, 4.5KG CAPACITY UNLESS OTHERWISE STATED		ILLUMINATED EXIT SIGN, LETTERING 75MM UNLESS OTHERWISE STATED
	30 MIN (UNLESS OTHERWISE STATED) FIRE AND SMOKE RESISTING DOORSET WHICH IS SELF-CLOSING AND PROVIDED WITH N6 NOTICES ON EACH SIDE OF THE DOOR	VL	VAPOURISING LIQUID EXTINGUISHER (HALON CF), 2.5KG CAPACITY UNLESS OTHERWISE STATED	E	EXIT SIGN, LETTERING 75MM UNLESS OTHERWISE STATED
		AF ₃	MULTI PURPOSE SPRAY (AFFF), 5L CAPACITY UNLESS OTHERWISE STATED	N1	GENERAL FIRE NOTICE
	30 MIN (UNLESS OTHERWISE STATED) FIRE AND SMOKE RESISTING DOORSET, AND PROVIDED WITH A N3 NOTICE ON THE OUTSIDE OF THE DOOR	B	FIRE BLANKET, 1M X 1M UNLESS OTHERWISE STATED	N2	STAFF FIRE NOTICE
	FIRE ALARM VISUAL WARNING DEVICE	SB	SAND BUCKET	N3	FIRE DOOR KEEP LOCKED SHUT
SC	SELF CLOSING DOOR	HHP	HEAD HEIGHT PARTITION	N4	SLIDE TO OPEN, LETTERING 75MM UNLESS OTHERWISE STATED
A	SELF CLOSING DOOR ON AUTOMATIC ACTUATION	FRG	FIRE RESISTING GLAZING	N5	FIRE EXIT DO NOT OBSTRUCT, LETTERING 50MM UNLESS OTHERWISE STATED
RS	ROLLER SHUTTER DOOR		FIRE ALARM / ZONE INDICATOR PANEL	N6	FIRE DOOR KEEP SHUT
VL	VERTICAL LADDER	E →	DIRECTIONAL EXIT SIGN, LETTERING 75MM UNLESS OTHERWISE STATED	N7	PUSH BAR TO OPEN NOTICE, LETTERING AT LEAST 50MM IN HEIGHT UNLESS OTHERWISE STATED
	SECURITY LOCK APPROVED TYPE		FIRE ALARM ACTUATING POINT	N8	AUTOMATIC DOOR KEEP CLEAR, SHOULD BE PROVIDED ON THE VISIBLE SIDE OF THE DOOR WHEN IN THE OPEN POSITION
PB	PUSH BAR IRONMONGERY, TOGETHER WITH A N7 NOTICE POSITIONED BELOW THE PUSH BAR		FIRE ALARM SOUNDER	Hr 1	HANDRAIL, AT LEAST 840MM IN HEIGHT UNLESS OTHERWISE STATED
VP	VISION PANEL, MEASURING AT LEAST 455MM X 455MM UNLESS OTHERWISE STATED		SMOKE DETECTOR	Gr 1	GUARDRAIL, AT LEAST 1070MM IN HEIGHT UNLESS OTHERWISE STATED
	HOSEREEL 30M LONG, UNLESS OTHERWISE STATED		HEAT DETECTOR		EMERGENCY LIGHT DIRECTIONAL
	WATER EXTINGUISHER, 9L CAPACITY UNLESS OTHERWISE STATED		EMERGENCY LIGHTING POINT	*	DOORS NOT FORMING PART OF MEANS OF ESCAPE
	FOAM EXTINGUISHER, 9L CAPACITY UNLESS OTHERWISE STATED		NORMAL LIGHTING POINT		SMOKE DETECTOR WITH SOUNDER
	DRY POWDER EXTINGUISHER, 10KG CAPACITY UNLESS OTHERWISE STATED		ACTUATING SWITCH FOR NORMAL LIGHTING POINT		HEAT DETECTOR WITH SOUNDER